

Lonedell R-14 School District Lead Water Testing



Location Number	Location	Level Detected
1	Drinking Fountain	.001
2	Popcorn Room Sink	.005
3	PreK Drinking Fountain	.001
4	Drinking Fountain	.001
5	Drinking Fountain	.002
6	Nurse's Sink	.002
7	Drinking Fountain	.001
8	Drinking Fountain	.001
9	Concession Stand Sink	.002
10	Lobby Drinking Fountain	ND
11	Gym Drinking Fountain	ND
12	Drinking Fountain	ND
13	Drinking Fountain	.001
14	FACS Sink	.003
15	Drinking Fountain	ND
16	Teacher Lounge Sink	.002
17	Kitchen Sink	.002
18	Cafeteria Drinking Fountain	.001
19	Ice Machine	.001

Maximum Level Allowed by Law =15 parts per billion (0.015 mg/L)

This table summarizes the lead testing results for the various locations throughout Lonedell Elementary School. The Popcorn Room Sink shows the highest detected level at 0.005 mg/L, which is still below the EPA action level of 0.015 mg/L.

ND=Not Detected

Four locations had lead levels below the detectable limit.